



OFFICE OF THE DISTRICT FIRE OFFICER  
SARJAPUR ROAD FIRE STATION  
KAIKONDRAHALLI BANGALORE-560 035.



Email:dfosarjapur99@gmail.com

Telephone No: 080-25746123

C.NO: 59/DFO/SRFS/BNG/CC/2023.

OFFICE OF THE DISTRICT FIRE OFFICER  
Karnataka State Fire & Emergency Service  
Sarjapura Road Fire Station  
Bangaluru-560 035.

Date: 23/06/23

"Annexure-2"

To,

*The Authorized Signatory*

NEW OXFORD SCHOOL (R)

Managed by Sarjapura Sri Krishna Education Society

Dodda Thimmasandra Sarjapura post,

Anekal talaku, Bangalore-562 125.

Sir,

*Sub:* Issue of "Fire Safety Compliance report" with respect to fire prevention, fighting and evacuation measures maintained at to "M/s. NEW OXFORD SCHOOL (R), Dodda Thimmasandra Sarjapura post, Anekal talaku, Bangalore-562 125".

Ref: 1) This office FSR No.59/DFO/SRFS/BNG/FSR/2023. Dt:-23-06-2023.

2) Your request letter dated: 21-06-2023.


3) Inspection Report:- 34/Fso/srfs/Bng/2023; Dated: 23-06-2023

<<<>>>

With reference to the above cited subject, as per reference (1) a conditional Fire Safety Recommendation was issued to the premises of "M/s. NEW OXFORD SCHOOL (R), Dodda Thimmasandra Sarjapura post, Anekal talaku, Bangalore-562 125". With a Condition to fulfill the recommendations and compliance the same within 3 months,

With reference cited (2) above, the management of "M/s. NEW OXFORD SCHOOL (R)" had requested for the fire safety compliance report from our department. In this regard the above addressed educational building was inspected by FSO Sarjapura road fire Station on 22/06/2023 for issue fire safety Compliance report.

Under the above circumstance the Karnataka Fire & Emergency Services Department is issuing the "Fire Safety Compliance Report" to. "M/s. NEW OXFORD SCHOOL (R), Dodda Thimmasandra Sarjapura post, Anekal talaku, Bangalore-562 125". Subject to proper maintenance of fire fighting installations in the good working conditions and arrange for 40% of staffs/ employees are training within 03 months from the date of issue of this report. "This report is valid for one year from the date of issue of this report and is renewable without fail".



Yours faithfully,

*[Signature]*

DISTRICT FIRE OFFICER  
Sarjapura Road Fire Station  
Bangaluru-560 035.

*[Signature]*  
PRINCIPAL

NEW OXFORD SCHOOL

Dodda Thimmasandra, Sarjapura (R)  
Anekal Taluk Bangalore Dist-562125

*[Signature]*

SECRETARY

Sarjapura Sri Krishna Education Society

D.No.22/1, Thimmasandra Road,

Sarjapura, Anekal Taluk,

Bangalore Dist-562125.





**OFFICE OF THE DISTRICT FIRE OFFICER  
SARJAPUR ROAD FIRE STATION  
KAIKONDRAHALLI BANGALORE-560 035.**



Email:dfosrfs@ksfes.gov.in

Telephone No: 080-25746123

**C.NO: 59/DFO/SRFS/BNG/FSR-2023.**

OFFICE OF THE DISTRICT FIRE OFFICER  
Karnataka State Fire & Emergency Service  
Sarjapura Road Fire Station  
Bangalore-560 035.

Date: 23/06/23

To,

*The Authorized Signatory*

NEW OXFORD SCHOOL (R)

Managed by Sarjapura Sri Krishna Education Society

Dodda Thimmasandra Sarjapura post,

Anekal talaku, Bangalore-562 125.

**ANNEXURE-B**

***Group B Educational Buildings***

Sub: Issue of "Fire Safety Recommendation Certificate" to "M/s. NEW OXFORD SCHOOL (R) Dodda Thimmasandra Sarjapura post, Anekal talaku, Bangalore-562 125.

Ref: 1) Your request letter dated: 21-06-2023.

2) Inspection Report:- 34/Fso/srfs/Bng/2023; Dated: 23-06-2023

><<<\*><<<

With reference to the subject cited above, the premises "M/s. New Oxford School, Dodda Thimmasandra, Sarjapur Post, Anekal Taluk, Bangalore-562 125". Was inspected by FSO Sarjapur Road Fire Station on **22-06-2023** with respect to fire prevention, fire fighting & evacuation measures to be complied in the above Premises and has submitted The details as Under.

**A. Details of the building / premises :-**

01	Name and Address of the Applicant.	:	The principal, NEW OXFORD SCHOOL (R) Managed by Sarjapura Sri Krishna Education Society Dodda Thimmasandra Sarjapura post, Anekal talaku, Bangalore-562 125.
02	Name and Address of the premises.	:	M/s. New Oxford School, Dodda Thimmasandra, Sarjapura post, Anekal talaku, Bangalore-562 125.
03	Name and address of the Building owner	:	Managing Society Sarjapura Sri Krishna Education Society, Dodda Thimmasandra,

**SECRETARY**  
Sarjapura Sri Krishna Education Society


D.No.22/1, Thimmasandra Road,  
Sarjapura, Anekal Taluk,  
Bangalore Dist-562125.



**NEW OXFORD SCHOOL**  
Dodda Thimmasandra, Sarjapura (R)  
Anekal Taluk, Bangalore Dist-562125



			Sarjapura post, Anekal talaku, Bangalore-562 125.
04	Number of buildings	:	One Building
05	Number of floors	:	Ground and 3 upper floors.
06	<b><u>Floor-wise details of occupancy:-</u></b>		
	Ground floor	:	10 class rooms, 01 Book room and 02 wash rooms.
	1 <sup>st</sup> floor	:	10 class rooms, 01 Book room and 02 wash rooms.
	2 <sup>nd</sup> floor	:	10 class rooms, 01 Book room and 02 wash rooms.
	3 <sup>rd</sup> floor	:	10 class rooms, 01 Book room and 02 wash rooms.
07	Height of the building	:	13.80 Mtrs.
08	Site area	:	9,054.79 Sq Mtrs.
09.	<b>Built-up area of each floor:-</b>		
	Ground floor	:	972.60 Sq. Mtrs.
	1 <sup>st</sup> floor	:	972.60 Sq. Mtrs.
	2 <sup>nd</sup> floor	:	972.60 Sq. Mtrs.
	3 <sup>rd</sup> floor	:	972.60 Sq. Mtrs.
10.	<b>Total built-up area</b>	:	<b>3,890.40 Sq. Mtrs.</b>
11.	<b><u>Surrounding properties:-</u></b>		
	East (Front)	:	06.00 Mtrs wide Sarjapur-thimmasandra road.
	West (Rear)	:	Vacant land
	North (side)	:	Vacant land
	South (side)	:	Vacant land.
12.	<b><u>Set-back area available around the building :-</u></b>		
	East (Front)	:	07.20 mtrs
	West (Rear)	:	01.00 mtrs
	North (side)	:	3.50 mtrs
	South (side)	:	1.70 mtrs

  
**SECRETARY**  
 Sarjapura Sri Krishna Education Society  
 D.No.22/1, Thimmasandra Road,  
 Sarjapura, Anekal Taluk,  
 Bangalore Dist-562125.



  
**PRINCIPAL**  
**NEW OXFORD SCHOOL**  
 D.No.22/1, Thimmasandra, Sarjapura (U)  
 Anekal Taluk, Bengaluru Dist-562125

B. On inspection of this Industrial premises, the following fire prevention, fire fighting and evacuation measures recommended are considered absolutely essential from fire safety point of view :-

Sl. No. (1)	Details (02 )	Existing (03 )			Recommendations (04 )
01.	Accessibility to the premises	06.00 mtrs wide Sarjapur- Dodda thimmasandra road located on Eastern side the road is hardened to carry the Weight of 45.000 Kgs.			Adequate
02.	No. of entrances	01 entrances/ exit			Complied
03.	Width of entry / exit	Each entrance is 08.50mtrs has been provided.			Adequate
04.	Diesel generators.	One generators of 50 KVA Capacity has been provided			Complied
05.	No. of staircases available	Nos. of staircases	:	03	Complied
		Width of staircases	:	Each of 02.00 mtrs	
		Width of treads	:	30 cm	
		Height of risers	:	15 cm	
		Nos. of riser per flight	:	12	
		Height of handrails	:	0.87 mtrs	
		Head room clearance	:	3.00mtrs	
06.	No. lifts and capacity.	Nos. of lifts	:	---	Complied
		Capacity of lifts	:	---	
07.	Fire extinguisher	15 Nos. of ABC fire extinguishers, each Of 4.5 kg capacity, 04 No's Of Co2 fire extinguishers each of 6 kg capacity has been provided in The Building.			Complied
08.	First aid Hose reel hose.	One Hose Reel Hose has been provided near the entrance gate, Hose Reel Hose of 19 mm size of adequate length to reach the farthest point of floor has been provided			Complied

<

*Dr. Revishan*  
**SECRETARY**  
 Sarjapura Sri Krishna Education Society  
 D.No.22/1, Thimmasandra Road,  
 Sarjapura, Anekal Taluk,  
 Bangalore Dist-562125.

*M. S. S.*  
**PRINCIPAL**  
**NEW OXFORD SCHOOL**  
 D.No.22/1, Thimmasandra, Sarjapura  
 Anekal Taluk Bangalore Dist-562125



		with shut off branch having a nozzle of 5 mm size. Have been Provided.	
09.	Terrace tank over respective tower terrace.	20,000 liters capacity of terrace tank has been provided.	Complied
10.	At the terrace tank level with minimum pressure of 3.5 kg/cm <sup>2</sup> .	A booster pump has been installed at the terrace level capable of delivering 450 liters of water per minute.	Complied
11.	Escape routes	Escape routes have been Marked in Which visibly to guide the students make to safer Places.	Complied
12.	No Smoking board.	No Smoking board shall be displayed.	Complied
13.	Fire Siren	A Fire Siren has been installed inside the premises to inform all the inmates in case of a fire emergency and evacuate the area.	Complied
14.	Nominate one fire Nodal Officer	One non teaching staff has been nominated as fire nodal officer for the school premises.	Complied
15.	Fire order	A notice board has been displayed the Action to be taken by the school staffs in Case of an <b>emergency with Telephone Numbers of Sarjapur Road Fire Station i.e. 25746166 &amp; 101</b> and telephone numbers of nearest Ambulance Service & Management Has been displayed.	Complied
16.	Fire fighting training	Not trained	The staff or employees Should be got trained in fire prevention And fire fighting evacuation measures at R.A.Mundkur Fire & Emergency Services Academy, B.G.Road, Bangalore-29.

*N. Kesavanna*  
**SECRETARY**  
 Sarjapura Sri Krishna Education Society  
 D.No.22/1, Thimmasandra Road,  
 Sarjapura, Anekal Taluk,  
 Bangalore Dist-562125.



*[Signature]*  
**PRINCIPAL**  
**NEW OXFORD SCHOOL**  
 D.No.22/1, Thimmasandra, Sarjapura (1)  
 Anekal Taluk Bangalore Dist-562125.

17. General Fire precaution measures :-


- A. Explosive and flammable materials should not be stored in the store room, UPS room, Electrical panel area, class rooms, laboratory & electrical sum panel premises.
- B. Accumulation of combustible waste in and around the premises should be avoided.
- C. The exit ways shall be always kept clear without any obstruction.
- D. Liquefied petroleum gas should be not stored in the building.
- E. The doors shall not be kept locked/latched during working hours and shall be free from obstruction.
- F. During the class hours the class room doors shall not be locked from inside to outside.
- G. As per Hon'ble Supreme Court order all teacher and staff shall be trained to handle safety equipment, initiate emergency evacuation and protect their students in the event of fire and other emergency and the school shall observe the Fire Safety day on April 14<sup>th</sup> of every year by conducting fire safety drills with co-ordinate with Fire Service Department.
- H. This Fire Safety Recommendation is issued from the fire prevention, fire fighting and evacuation measures. Karnataka State Fire & Emergency Services Department is not responsible for the ownership of the land, its location and other disputes, which may arise in due course.

Under the above circumstance, the Karnataka Fire & Emergency Services Department is issuing "Fire Safety Recommendation" to "M/s New Oxford School(R), Dodda Thimmasandra, Sarjapur Post, Anekal Taluk, Bangalore-562 125". Subject to condition and compliance of the above recommendations as shown in Column-4 of Part-B within 3 months and compliance from the undersigned.

"This Fire Safety Recommendation is valid for Only One Year from the date of issue and it is renewable."

All requirements recommended above are as per National Building Code-2016 Part-4 clause 3.1.3 of Fire and Life safety will have to be complied with mandatorily.

Yours faithfully,

  
DISTRICT FIRE OFFICER  
Sarjapura Road Fire Station  
Bangalore-560 035.

  
SECRETARY  
Sarjapura Sri Krishna Education Society  
D.No.22/1, Thimmasandra Road,  
Sarjapura, Anekal Taluk,  
Bangalore Dist-562125.

  
PRINCIPAL  
NEW OXFORD SCHOOL  
Dodda Thimmasandra, Sarjapura (+  
Anekal Taluk, Bangalore Dist-562125.