



**OFFICE OF THE DISTRICT FIRE OFFICER**  
KARNATAKA STATE FIRE & EMERGENCY SERVICES  
**SECRETARIAT FIRE STATION**



VikasaSoudha, Vidhana Soudha Premises, Bengaluru-560001.  
Gmail: dfoscretariat@gamil.com Tel: 080-22971603/602.

No.07/RFSCR/DFO/SVFS/BEN/2025.

Dated:24-06-2025

**"Annexure-B"**

**To,**

**M/s. New Oxford School®**

**Managed By Sarjapura Sri Krishna education Society**

**Dodda Thimmasandra Sarajapura, anekal Tq**

**Sarjapura Post, Bengaluru-560075.**

*Sir,*

**Sub:** Renewal of Fire Safety Compliance Report with respect to prevention, fire Fighting and Evacuation measures maintained at **New Oxford School®, Dodda Thimmasandra Sarajapura, anekal Tq Sarjapura Post, Bengaluru-75**

Ref: 1)No.59/DFO/SRFS/BNG/BAN/FSR/2023

Dt:23-06-2023

2)No. 59/DFO/SRFS/BNG/BAN/CC/2023

Dt:23-06-2023

3) Request letter dt:20-06-2025.

4)No.07/RFSCR/FSO/SVFS/BEN/2025.

Dt:23-06-2025

<<<>>>

With reference to the subject cited above, as per reference (1) a conditional Fire Safety Recommendations was issued to the premises of at **New Oxford School®, Dodda Thimmasandra Sarajapura, anekal Tq Sarjapura Post, Bengaluru-75**. With a condition to fulfill the recommendations and compliance the same within 3 months.

As per reference (2) the Fire Safety compliance certificate was issued to the premises of at **New Oxford School®, Dodda Thimmasandra Sarajapura, anekal Tq Sarjapura Post, Bengaluru-75**.

*N. Kesitha*  
**SECRETARY**

**SARJAPURA SRI KRISHNA  
EDUCATION SOCIETY (R)**  
Dodda Thimmasandra Road  
Sarjapura, Anekal Taluk  
BENGALURU-562125



*N. Kesitha*  
**PRINCIPAL**  
**NEW OXFORD SCHOOL**  
Dodda Thimmasandra, Sarjapura Post  
Anekal Taluk, Bengaluru Dist-562125

As per reference (3) at New Oxford School®, Dodda Thimmasandra Sarajapura, anekal Tq Sarjapura Post, Bengaluru-75. Had requested to renewal of Fire Safety Compliance Report In this regard as per reference (4) the above School building was inspected by Fire Station Officer, Secretariat Fire Station on 23-06-2025 and submitted the report.

Under the above Circumstances the Karnataka Fire & Emergency Services Department is Renewal of Fire Safety Compliance Report issued to New Oxford School®, Dodda Thimmasandra Sarajapura, anekal Tq Sarjapura Post, Bengaluru-75. Subject to proper maintenance of fire fighting installations in good working conditions and arrange for 40% of staffs/employees training within 03 months from the date of issue of this report.

**"This report is valid for Two year from the date of issue and is renewable without fail".**

Yours Faithfully

*[Handwritten Signature]* 23/06/25

**DISTRICT FIRE OFFICER  
KARNATAKA FIRE & EMERGENCY SERVICES  
SECRETARIAT FIRE STATION  
BANGALORE - 01**

*[Handwritten Signature]*  
**SECRETARY**

**SARJAPURA SRI KRISHNA  
EDUCATION SOCIETY (R)**  
Dodda Thimmasandra Road  
Sarjapura, Anekal Taluk  
BENGALURU-562125

*[Handwritten Signature]*  
**PRINCIPAL**

**NEW OXFORD SCHOOL**  
Dodda Thimmasandra, Sarjapura Post  
Anekal Taluk, Bengaluru Dist-562125